



Giganet External Battery Pack Extended Runtime Sheet

External Battery Pack - Rack Mounted (EBP) for 1,2,3,6 &10 KVA UPS's					
		Backup Time with No. of Giganet EBP Required for Full Load			
Giganet UPS Type	Giganet EBP Part No.	15 Minutes	30 Minutes	45 Minutes	60 Minutes
GN-UPS-1KVAS-RT	GN-EBP-1KVA-0424V-RT	1	2	3	4
GN-UPS-2KVAS-RT	GN-EBP-2KVA-0848V-RT	1	2	3	4
GN-UPS-3KVAS-RT	GN-EBP-3KVA -1272V-RT	1	2	3	4
GN-UPS-6KVAX-RT	GN-EBP-6-10KVA-20120V-RT	2	3	5	Achieved with Battery
GN-UPS-10KVAX-RT	GN-EBP-6-10KVA-20120V-RT	3	5	Achieved with Battery	Achieved with Battery

Note: 1) The Batteries inside the External Battery Packs are VRLA batteries and only to be used with Giganet UPS as mentioned above.

2) Recommended External Battery Packs(EBP) extended runtime upto 60 minutes only. Giganet External batteries should be used to achieve backup time beyond 60 minutes. [Click here to check External Batteries Extended Runtime Sheet](#)

3) X to be replaced with S for in-built batteries

H for without in-built batteries.

All Rights Reserved. This document is subject to change without any prior notice.

GIGANET NETWORKING SOLUTIONS LTD | 9 De Montfort Street | Leicester | LE1 7GE | UK

Telephone: +44 (0) 208 897 0346 Fax: +44(0)844 822 2456 Email: sales@giga-net.co.uk Web: www.giga-net.co.uk